



Proposed Licensing Plan  
Scale 1:50

FIRE ALARM AND SMOKE DETECTION SYSTEM	
FIRE ALARM TO BE DEVICES TO COMPLY WITH AS/NZS 1841:1 (2014) (RELEVANT) LOCATED TO BE DELIVERED TO COMPLY WITH AS/NZS 1841:1 (2014) INDICATIVE LAYOUT ONLY	
	FIRE ALARM BREAK GLASS
	LANDLORD FIRE ALARM INTERFACE PANEL
	FIRE ALARM REPEATER PANEL
	FIRE ALARM PANEL (FIRE ALARM TO BE S692201)
	DUAL OPTICAL AND HEAT MULTISENSOR AND VOICE
	DUAL OPTICAL AND HEAT MULTISENSOR AND VOICE AND STROBE
	DUAL OPTICAL AND HEAT MULTISENSOR IN CEILING/FLOOR VOID
	HEAT SENSOR AND STROBE AND VOICE
	RW-100 FULLY MAINTAINED FITTING IN MAINS & BATTERY (INCLUDING HEATING WIRE TO BELL)
	RW-100 FULLY MAINTAINED FITTING IN MAINS & BATTERY
	EMERGENCY LIGHT FITTING RECESSED RW-100 FULLY MAINTAINED FITTING IN MAINS & BATTERY
	EMERGENCY LIGHT FITTING SURFACE RW-100 FULLY MAINTAINED FITTING IN MAINS & BATTERY
	SECURITY ALARM KEYPAD
	LAST MAN OUT SWITCH
	ANSUL FIRE SUPPRESSION SYSTEM
	RED LINE INDICATES LICENSED AREA

  

FIRE APPLIANCES	
	FIRE BLANKET IN CONTAINER
	CARBON DIOXIDE FIRE EXTINGUISHER
	9 LITRE WATER EXTINGUISHER
	WET CHEMICAL EXTINGUISHER
	FOAM FIRE EXTINGUISHER

www.ablankcanvasinteriors.co.uk		01225252525	
Unit 22, Endeavour Business Park, Church Hill Lane, Ringwood BH24 1DP			
Date	Feb 2019	Client	Austin Whelan
Drawn	AB	Project	The Black Bull
Checked	+	Project	Victoria Road
Scale	1:50 @ A0	Project	Roundup
		Project	HAM ODE
Proposed Licensing Plan			

Rev	Scale	Notes
A	1:50	External Bar settings

Drawing no.

**L01**

The

A